



TankScan®

The power of data. **Optimized.**

Optimization of Fluid Management in Aboveground Storage Tanks

November 12, 2015

Introduction

- Mike Murray, ATEK Access Technologies
 - Director of TankScan Sales
 - Four years in the field with tank users - waste oil generators and collectors, lube and fuel distributors, oil fields, and chemical storage
 - Formerly managed fuel cooperative with bulk storage sites
 - Over 20 years of experience in automotive repair business, used oil generator




Optimization of Fluid Management in ASTs

- There are over 18 million aboveground storage tanks (ASTs) in the US alone
 - Many different uses in several vertical markets
 - Multiple sizes and configurations



Optimization of Fluid Management in ASTs

- Three Issues Important to NORA Members
 - Compliance
 - Safety
 - Inventory management



Optimization of Fluid Management in ASTs

- Compliance
 - Goals for facilities with large amounts of oil
 - Prevent environmental damage
 - Avoid loss of product
 - Avoid civil law suits
 - Avoid costly clean up measures
 - Hazardous waste requirements
 - EPA
 - Comply with EPA's Spill Prevention Control and Countermeasure (SPCC) regulations
 - State and local regulations




Optimization of Fluid Management in ASTs

- Everyone Knows
 - EPA has several regulations that apply to used oil handling
 - Single walled ASTs should have secondary containment
 - Contains spills
 - Allows leaks to be easily detected
 - Containment must hold 110% of contents of largest AST
 - Must be impermeable to the materials being stored
 - Many states require the secondary containment interstitial space be checked regularly for leakage
 - Can be done manually, hand recorded for required record-keeping
 - Technology is available to automate both level measurement and interstitial space compliance



Optimization of Fluid Management in ASTs

- Less Well Known
 - Largest citation categories
 - Tanks marked incorrectly
 - Must be “Used Oil”
 - NOT “Waste Oil”
 - Incorrect paperwork
 - Annual reports
 - Help generators know the rules
 - Value-add service to generator accounts




Optimization of Fluid Management in ASTs

- Problem: Overfill Protection
 - Some states require for bulk storage tanks
- Technology Solutions
 - High level alarm
 - Can be electronic or manual
 - Only serve single function
 - Electronic tank monitor
 - Serves for both overfill protection and tank level
 - Tank levels can be checked before fills
 - Daily inventory records kept automatically



Optimization of Fluid Management in ASTs

- Three Issues Important to NORA Members
 - Compliance
 - **Safety**
 - Inventory management



Optimization of Fluid Management in ASTs

- Safety
 - Many safety concerns in tank farms are due to manual tank measurement
 - Employees climbing tanks to measure them and falls occur
 - Inadvertently inhaling toxic fumes
 - Trips and falls when walking through crowded tank farms
 - Best practices
 - Mechanical, site or electronic tank gauges reduce risks
 - Keeping tank farm floor clean and dry



Criticality of Safety Measures


- True Story....
 - Deaths of 10 tank workers over last five years have haunting similarities
 - All in jobs requiring climbing on tanks and opening the hatch
 - All in remote locations operating alone
 - No known witnesses to deaths – all found laying on or around the tanks
 - Four of the workers involved in tank gauging, five others in sampling the tank contents
 - Causes were all initially ruled as natural, heart failure
 - Safety experts and government regulators are now acknowledging a pattern
 - Now focused on the possible role of hydrocarbon-based fumes
 - Can lead to quick asphyxiation when inhaled in large quantities
 - Government now sending out warnings
 - Many in the industry remain ignorant of possible risks
 - Recommending automating as many of the tasks as possible

Startling Photo



Optimization of Fluid Management in ASTs

- Three Issues Important to NORA Members
 - Compliance
 - Safety
 - **Inventory management**



Optimization of Fluid Management in ASTs

- Inventory Management
 - Effective system benefits
 - Reduce shrinkage
 - Prevent billing or accounting errors
 - Make better business decisions
 - Automate compliance requirement reporting
 - Consistent and accurate system requirements
 - Daily inventory of product levels
 - Daily reconciliation of additions and extractions from ASTs
 - Efficient method of tracking and storage of the data
 - Technologies available to optimize best practices
 - Electronic tank monitoring with web-based portals for continual access
 - Back office or inventory management software
 - Data warehouse integration



Superior Lubricants Case Study

- Matt Gudorf, NORA Member and Chief Managing Officer of Superior Lubricants
- Three Locations
 - North Tonawanda, NY
 - Syracuse, NY
 - Kitchener, Ontario
- Reliance Fluid Technologies, Sister Company
 - Niagara Falls, NY



Superior Lubricants Case Study

- Problem: Compliance
 - New York State EPA Requirements
 - High level alarms on bulk storage tanks
 - Cost of \$1,200 each plus installation
 - Recordkeeping of inventory levels
 - Manual method is time consuming and labor intensive
- Solution
 - The use of technology for automation
 - Installed wireless tank monitors
- Result
 - Satisfied EPA regulations
 - Inventory levels are automatically taken multiple times a day



Superior Lubricants Case Study

- Problem: Inventory Management
 - Previous method was manual
 - Time consuming and costly
 - Subject to inaccuracy and human error
 - Only performed weekly
 - Inefficiently hand written and faxed
- Solution
 - The use of technology
 - Web-based information platform
 - Real-time access to accurate inventory levels
- Result
 - Now have the ability to understand daily and monthly usage
 - Superior can purchase only enough to ensure just-in-time deliveries
 - Saves on inventory investment

TankScan

Superior Lubricants Company

Home

Admin

Tanks

New

Status	Name	% Full	Empty	Full	Battery	Temperature	Capacity	Capacity UOM	Contents	Site																																																																													
Warning	ETF01	0%	15545.73 gals	0.00 gals	6.100 V	57.20 F	15500	Gallons	DSL SAE SYN BLEND SW30	East																																																																													
<div><div><div>0%</div></div><div><div>ETF01</div><div>Warning 0%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 8:55 AM</div><div>Location: Tank Farm</div></div></div> <div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>0%</div><div>2015/11/7 8:55 AM</div></div><div><div><div>Battery</div><div>6.100 V</div><div>2015/11/7 8:55 AM</div></div><div><div><div>Empty</div><div>15545.73 gals</div><div>2015/11/7 8:55 AM</div></div><div><div><div>Full</div><div>0.00 gals</div><div>2015/11/7 8:55 AM</div></div><div><div><div>Temperature</div><div>57.20 F</div><div>2015/11/7 8:55 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div><tr><td>Warning</td><td>ETF03</td><td>1%</td><td>15459.36 gals</td><td>86.36 gals</td><td>5.900 V</td><td>60.26 F</td><td>15500</td><td>Gallons</td><td>DSL SAE SYN BLEND SW30</td><td>East</td></tr><tr><td>Warning</td><td>ETF04</td><td>13%</td><td>13570.12 gals</td><td>1975.60 gals</td><td>5.800 V</td><td>57.20 F</td><td>15500</td><td>Gallons</td><td>Motorcraft SW20</td><td>East</td></tr><tr><td colspan="11"><div><div><div>13%</div></div><div><div>ETF04</div><div>Warning 13%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 8:11 AM</div><div>Location: Tank Farm</div></div></div><div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>13%</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Battery</div><div>5.800 V</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Empty</div><div>13570.12 gals</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Full</div><div>1975.60 gals</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Temperature</div><div>57.20 F</div><div>2015/11/7 8:11 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div><tr><td>Normal</td><td>ETF05</td><td>40%</td><td>9268.06 gals</td><td>6277.67 gals</td><td>5.900 V</td><td>60.98 F</td><td>15500</td><td>Gallons</td><td>DSL HYD RO/4W-LT 32</td><td>East</td></tr><tr><td>Normal</td><td>ETF06</td><td>61%</td><td>5986.18 gals</td><td>9559.54 gals</td><td>5.900 V</td><td>64.22 F</td><td>15500</td><td>Gallons</td><td>DSL HYD 32 FLUID</td><td>East</td></tr><tr><td>Normal</td><td>ETF10</td><td>58%</td><td>4220.73 gals</td><td>5866.25 gals</td><td>5.900 V</td><td>50.00 F</td><td>10000</td><td>Gallons</td><td>CAH2 DEVOS1 SW20</td><td>East</td></tr><tr><td colspan="11"><div><div><div>58%</div></div><div><div>ETF10</div><div>Normal 58%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 7:48 AM</div><div>Location: Tank Farm</div></div></div><div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>58%</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Battery</div><div>5.900 V</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Empty</div><div>4220.73 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Full</div><div>5866.25 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Temperature</div><div>50.00 F</div><div>2015/11/7 7:48 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div></div></div></div></div></td></tr></div></div></div></div></td></tr></div></div></div></div>											Warning	ETF03	1%	15459.36 gals	86.36 gals	5.900 V	60.26 F	15500	Gallons	DSL SAE SYN BLEND SW30	East	Warning	ETF04	13%	13570.12 gals	1975.60 gals	5.800 V	57.20 F	15500	Gallons	Motorcraft SW20	East	<div><div><div>13%</div></div><div><div>ETF04</div><div>Warning 13%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 8:11 AM</div><div>Location: Tank Farm</div></div></div> <div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>13%</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Battery</div><div>5.800 V</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Empty</div><div>13570.12 gals</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Full</div><div>1975.60 gals</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Temperature</div><div>57.20 F</div><div>2015/11/7 8:11 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div><tr><td>Normal</td><td>ETF05</td><td>40%</td><td>9268.06 gals</td><td>6277.67 gals</td><td>5.900 V</td><td>60.98 F</td><td>15500</td><td>Gallons</td><td>DSL HYD RO/4W-LT 32</td><td>East</td></tr><tr><td>Normal</td><td>ETF06</td><td>61%</td><td>5986.18 gals</td><td>9559.54 gals</td><td>5.900 V</td><td>64.22 F</td><td>15500</td><td>Gallons</td><td>DSL HYD 32 FLUID</td><td>East</td></tr><tr><td>Normal</td><td>ETF10</td><td>58%</td><td>4220.73 gals</td><td>5866.25 gals</td><td>5.900 V</td><td>50.00 F</td><td>10000</td><td>Gallons</td><td>CAH2 DEVOS1 SW20</td><td>East</td></tr><tr><td colspan="11"><div><div><div>58%</div></div><div><div>ETF10</div><div>Normal 58%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 7:48 AM</div><div>Location: Tank Farm</div></div></div><div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>58%</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Battery</div><div>5.900 V</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Empty</div><div>4220.73 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Full</div><div>5866.25 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Temperature</div><div>50.00 F</div><div>2015/11/7 7:48 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div></div></div></div></div></td></tr></div></div></div></div>											Normal	ETF05	40%	9268.06 gals	6277.67 gals	5.900 V	60.98 F	15500	Gallons	DSL HYD RO/4W-LT 32	East	Normal	ETF06	61%	5986.18 gals	9559.54 gals	5.900 V	64.22 F	15500	Gallons	DSL HYD 32 FLUID	East	Normal	ETF10	58%	4220.73 gals	5866.25 gals	5.900 V	50.00 F	10000	Gallons	CAH2 DEVOS1 SW20	East	<div><div><div>58%</div></div><div><div>ETF10</div><div>Normal 58%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 7:48 AM</div><div>Location: Tank Farm</div></div></div> <div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>58%</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Battery</div><div>5.900 V</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Empty</div><div>4220.73 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Full</div><div>5866.25 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Temperature</div><div>50.00 F</div><div>2015/11/7 7:48 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div></div></div></div></div>										
Warning	ETF03	1%	15459.36 gals	86.36 gals	5.900 V	60.26 F	15500	Gallons	DSL SAE SYN BLEND SW30	East																																																																													
Warning	ETF04	13%	13570.12 gals	1975.60 gals	5.800 V	57.20 F	15500	Gallons	Motorcraft SW20	East																																																																													
<div><div><div>13%</div></div><div><div>ETF04</div><div>Warning 13%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 8:11 AM</div><div>Location: Tank Farm</div></div></div> <div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>13%</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Battery</div><div>5.800 V</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Empty</div><div>13570.12 gals</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Full</div><div>1975.60 gals</div><div>2015/11/7 8:11 AM</div></div><div><div><div>Temperature</div><div>57.20 F</div><div>2015/11/7 8:11 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div><tr><td>Normal</td><td>ETF05</td><td>40%</td><td>9268.06 gals</td><td>6277.67 gals</td><td>5.900 V</td><td>60.98 F</td><td>15500</td><td>Gallons</td><td>DSL HYD RO/4W-LT 32</td><td>East</td></tr><tr><td>Normal</td><td>ETF06</td><td>61%</td><td>5986.18 gals</td><td>9559.54 gals</td><td>5.900 V</td><td>64.22 F</td><td>15500</td><td>Gallons</td><td>DSL HYD 32 FLUID</td><td>East</td></tr><tr><td>Normal</td><td>ETF10</td><td>58%</td><td>4220.73 gals</td><td>5866.25 gals</td><td>5.900 V</td><td>50.00 F</td><td>10000</td><td>Gallons</td><td>CAH2 DEVOS1 SW20</td><td>East</td></tr><tr><td colspan="11"><div><div><div>58%</div></div><div><div>ETF10</div><div>Normal 58%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 7:48 AM</div><div>Location: Tank Farm</div></div></div><div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>58%</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Battery</div><div>5.900 V</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Empty</div><div>4220.73 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Full</div><div>5866.25 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Temperature</div><div>50.00 F</div><div>2015/11/7 7:48 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div></div></div></div></div></td></tr></div></div></div></div>											Normal	ETF05	40%	9268.06 gals	6277.67 gals	5.900 V	60.98 F	15500	Gallons	DSL HYD RO/4W-LT 32	East	Normal	ETF06	61%	5986.18 gals	9559.54 gals	5.900 V	64.22 F	15500	Gallons	DSL HYD 32 FLUID	East	Normal	ETF10	58%	4220.73 gals	5866.25 gals	5.900 V	50.00 F	10000	Gallons	CAH2 DEVOS1 SW20	East	<div><div><div>58%</div></div><div><div>ETF10</div><div>Normal 58%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 7:48 AM</div><div>Location: Tank Farm</div></div></div> <div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>58%</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Battery</div><div>5.900 V</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Empty</div><div>4220.73 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Full</div><div>5866.25 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Temperature</div><div>50.00 F</div><div>2015/11/7 7:48 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div></div></div></div></div>																																											
Normal	ETF05	40%	9268.06 gals	6277.67 gals	5.900 V	60.98 F	15500	Gallons	DSL HYD RO/4W-LT 32	East																																																																													
Normal	ETF06	61%	5986.18 gals	9559.54 gals	5.900 V	64.22 F	15500	Gallons	DSL HYD 32 FLUID	East																																																																													
Normal	ETF10	58%	4220.73 gals	5866.25 gals	5.900 V	50.00 F	10000	Gallons	CAH2 DEVOS1 SW20	East																																																																													
<div><div><div>58%</div></div><div><div>ETF10</div><div>Normal 58%</div><div>Vertical Cylinder</div><div>Last Report: 2015/11/7 7:48 AM</div><div>Location: Tank Farm</div></div></div> <div><div><div>Reading</div><div>Value</div><div>Date</div></div><div><div><div>% Full</div><div>58%</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Battery</div><div>5.900 V</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Empty</div><div>4220.73 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Full</div><div>5866.25 gals</div><div>2015/11/7 7:48 AM</div></div><div><div><div>Temperature</div><div>50.00 F</div><div>2015/11/7 7:48 AM</div></div></div><div><div><div>Zoom Map</div></div><div><div><div>View All</div><div>Details</div><div>Provisioning</div><div>Configure Monitor</div></div></div></div></div></div></div></div></div>																																																																																							

Superior Lubricants Case Study

- Problem: Need for Cost Savings and Efficiencies
 - EPA regulations for high level alarms
 - \$1,200 each plus install for 240 tanks across the organization (\$288,000 plus installation)
 - Manual inventory overtime expense of \$72 a week per location (\$10,368 annually)
 - Inefficient and inaccurate inventory control methods
- Solution
 - Installation of wireless tank monitors
 - Addressed all three issues
- Result
 - Superior Lubricants and Reliant Fluid Technologies
 - Committed to installing monitors on all bulk tanks



Optimization of Fluid Management in ASTs

- Conclusion
 - Compliance, safety and inventory management are all important issues in ASTs
 - Must be part of overall business plan around AST management
 - The use of industry best practices and technology can help solve the challenges efficiently



Contact Info and Questions

- Mike Murray, Director of TankScan Sales
- ATEK Access Technologies
 - mmurray@atekcompanies.com
 - www.tankscan.com



- Matt Gudorf, Chief Managing Officer
- Superior Lubricants
 - mdgudorf@superiorlubricants.com
 - www.superiorlubricants.com

