

White Paper

Line of Sight Requirements for Reliable Low-Power RF Communication

By: John Brewer,
Senior Electrical Design Engineer -
ATEK Access Technologies

Positioning low-power Radio Frequency (RF) communications equipment requires that special attention must be taken to ensure proper Line-of-Sight (LOS) clearance between the transmitter and receiver. In regards to the TankScan monitoring system, this means a clear path between the monitor, which mounts on top of a tank, and the gateway which can be mounted near any power source. Failure to provide a clear LOS can manifest itself in two ways: missed reports and a shortened battery life. The guidelines set forth in this white paper will allow you to choose mounting locations that will optimize signal strength and battery life.

Background

Line-of-sight is defined as the straight line distance, clear of any objects, between the gateway antenna and each monitor it communicates with. Poor communications between a gateway and any monitor can cause two adverse effects: missed reports and a shortened battery life. If a monitor has trouble communicating with a gateway it may have to re-establish a connection while reporting a level. This process prolongs radio on time and further drains the battery. If a connection cannot be established, the tank level reading will be skipped.

TSM8000 monitors and their X2e, X2, and X4 gateways operate at 2.4 GHz frequency band and contain 18 dB (63 mW) radios. In addition, the X2 and X4 models have an additional 2 dB of gain from their antennas to provide 100 mW of output power. This allows for a 1,000-ft range with true line-of-sight conditions. However, few installations have perfect line-of-sight and some installation guidelines need to be observed. The following information will aid in antenna installation and positioning.

WHITE PAPER

Many variables can affect the range of gateways and monitors; most prominent are obstructions blocking the signal path. The gateways are not intended for outdoor installation and must be placed indoors or inside an enclosure. This means that at least one obstruction (building wall, window, or enclosure wall) will exist between a gateway and any monitor unless an optional remote antenna is used, which reduces the 1,000-ft range. There is not an exact way to predict to what extent the range will be reduced, but there are a few general guidelines:

- **There may be up to 18 dB loss when sending radio signals through an exterior (non-metal) wall. The communication range may then be reduced to 125 ft. The type of wall (wood, concrete, masonry, brick or combination) and the thickness of wall affect this number.**
- **There may be up to 12 dB loss when communicating through a window. The communication range may then be reduced to 250 ft. The type of window, tinted, double-paned, thickness and frame are all factors that contribute to range loss.**
- **Trees and foliage also attenuate 2.4 GHz signals, so gateway to monitor line-of-sights that pass through trees and foliage should be avoided.**

It is not recommended to send radio signals through more than one window or non-metallic wall and never through a metal wall. A remote antenna should be used in these instances. This antenna can be used to improve the range and/or performance for other installations as well. Cable lengths of 10 ft to 100 ft (in 10 ft increments) are available, see table below for cable length versus radio signal range recommendations.

| CABLE LENGTH VERSUS RADIO SIGNAL RANGE | | | | |
|--|---------------|--------------|--------------|--------------|
| Cable Length (ft) | Range 1000 ft | Range 500 ft | Range 250 ft | Range 125 ft |
| 0 | ✓ | ✓ | ✓ | ✓ |
| 10 | ✓ | ✓ | ✓ | ✓ |
| 20 | ✓ | ✓ | ✓ | ✓ |
| 30 | ✓ | ✓ | ✓ | ✓ |
| 40 | NR | ✓ | ✓ | ✓ |
| 50 | NR | ✓ | ✓ | ✓ |
| 60 | NR | ✓ | ✓ | ✓ |
| 70 | NR | NR | ✓ | ✓ |
| 80 | NR | NR | ✓ | ✓ |
| 90 | NR | NR | ✓ | ✓ |
| 100 | NR | NR | NR | ✓ |

NR = Not Recommended

WHITE PAPER

Antenna Mounting Guidelines

The remote antenna should be installed at least 2½ inches from metal surfaces, such as walls and mounting poles, for best performance.

Ideally an antenna should have clear line-of-sight communication to all monitors. The farther an antenna is from a monitor the more critical this becomes. Radio signals do go through, reflect off, and refract around obstructions, but they lose strength and range each time it occurs.


The mounting bracket for the remote antennas is a simple, lightweight design. It can be mounted to a 2-inch maximum diameter pole, or to a wall or other flat surface and can be secured in a vertical or horizontal position. Optimal position is a vertical mounting.

TankScan remote antennas have a fat, concentric, donut-shaped propagation pattern (shown on right) so height differences between gateway antenna and monitors are not critical and may be installed at different heights. Vertical angles of up to 60 degrees between the gateway and monitor are acceptable.




The following examples show some of the various remote antenna mounting configurations. Every installation will be different, but it is important to maintain line-of-sight for each to provide the most robust communication.


Pipe Mounted on Roof of Building



Mounted to Building Corner



Mounted to Building Wall




WHITE PAPER


Clear Line-of-Sight

Often a gateway needs to talk to a cluster of tanks, sometimes positioned near obstructions such as other buildings, trees, or equipment. In these cases, a clear line-of-sight should be established to all monitors by picking an appropriate position for the gateway's antenna and/or raising the antenna up high enough to "see" all of the tank monitors.

Adequate antenna height above earth ground is important for successful radio communications. Radio signals propagate through the air in a zone shaped like a football, with the zone being very narrow at each antenna end and widest in the middle. As a very rough rule of thumb there should be 1 ft clearance radius (r) from all obstructions at the midpoint for every 100 ft of transmit distance.



In the example below communication to Tank 3 is probably not possible from the North, while Tank 2 may or may not be blocked by Tank 1 from the West. A good rule of thumb to follow is that if each monitor is within range and an observer can clearly see the gateway antenna from the monitor's position, they should be able to communicate.



Line of Sight Requirements for Reliable Low-Power RF Communication

WHITE PAPER

Indoor Installations

Many sites have tanks located within the same building as their gateway. Guidelines for signal strength and range loss within a building include:

- 2 dB to 9 dB loss when shooting through a sheet rock interior wall
- 2 dB to 6 dB loss when shooting through an office panel
- 2 dB to 6 dB loss when shooting through a rack of equipment

As a rule of thumb; every 6 dB of loss decreases signal range by 50 percent.

Indoor installations present unique conditions as there is less open space for a LOS clearance zone and the potential for much more interference. Line-of-sight communication is rarely possible. Because of the nature of indoor environments, it is recommended to limit the communication range to 250 ft.

Summary

For reliable monitor-to-gateway communication there are two basic rules:

- 1 Do not exceed radio signal range of gateways and monitors.
- 2 Establish clear line-of-sight communication between gateways and monitors using a remote antenna, if necessary.

| TYPICAL RANGES | | | | | |
|-------------------------------|-----------|--------------|----------------|--------|------------------------------|
| Gateway | LOS Range | Through Wall | Through Window | Indoor | LOS Range w/ Remote Antenna* |
| X2e | 500 ft | 125 ft | 250 ft | 250 ft | n/a |
| X2 (with provided antenna) | 1000 ft | 250 ft | 500 ft | 250 ft | 1000 ft |
| X4 (with provided antenna) | 500 ft | 125 ft | 250 ft | 250 ft | 1000 ft |

*Cable length< 20 ft

Following the guidelines set forth in this white paper will ensure proper line-of-sight clearance, resulting in reliable RF communication and expected battery life.

204-0003-000 Rev. B 8/12/2025

AquaPhoenix Scientific
860 Gitts Run Road
Hanover, PA 17331

PH: 877-847-7226

www.tankscan.com



AquaPhoenix®
S C I E N T I F I C

©2025 AquaPhoenix. All Rights Reserved. TankScan images and marketing materials are protected by various patents, copyrights and/or trademarks. AquaPhoenix assumes no responsibility for any errors which may appear in this document, reserves the right to change devices or specifications detailed herein at any time without notice, and does not make any commitment to update the information contained herein. No licenses to patents or other intellectual property of AquaPhoenix are granted by the Company in connection with the sale of TankScan products, expressly or by implication.