


TEK750 Battery Replacement Instructions

TankScan | Powered by AquaPhoenix

⚠ WARNING – EXPLOSION HAZARD: DO NOT REPLACE BATTERY PACK WHEN AN EXPLOSIVE ATMOSPHERE IS PRESENT. If necessary, remove monitor from tank and take to unclassified/non-hazardous area before removing enclosure cover. ⚠ USE ONLY BATTERIES PROVIDED BY ATEK!

Battery Replacement

- 1 Remove four screws on ears of monitor.
- 2 Remove cover from bottom half of monitor. Take care as there is a cable connecting cover to bottom half.
- 3 Remove used battery from holder. Its easiest to remove one side first.
- 4 Replace with new battery. Note orientation of battery. Replace only with ATEK part # TEKRB02000.
- 5 Reposition O-ring so it sits on top of ledge around bottom half of monitor.
- 6 Line up divot on cover with TankAlert sticker on bottom half and press together.
- 7 Retighten screws.



**For questions or problems –
Contact TankScan Technical Support,
877-847-7226**

223-0196-000 Rev. B 7/10



WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov

AquaPhoenix Scientific
860 Gitts Run Road
Hanover, PA 17331

PH: 877-847-7226

www.tankscan.com



AquaPhoenix®
S C I E N T I F I C

©2025 AquaPhoenix. All Rights Reserved. TankScan images and marketing materials are protected by various patents, copyrights and/or trademarks. AquaPhoenix assumes no responsibility for any errors which may appear in this document, reserves the right to change devices or specifications detailed herein at any time without notice, and does not make any commitment to update the information contained herein. No licenses to patents or other intellectual property of AquaPhoenix are granted by the Company in connection with the sale of TankScan products, expressly or by implication.